Surface mounting enclosure, 3 mounting locations



Part no. M22-13 Catalog No. 216538 Alternate Catalog M22-130

No.

EL-Nummer 4355386

(Norway)

Delivery program

| Delivery program | | |
|----------------------------|------|---|
| Basic function accessories | | Surface mounting enclosure |
| Housing | | Insulated material |
| | | With high-grade steel screws |
| Number of locations | Qty. | 3 |
| Cable entry knockouts | | |
| Cable entry | | rear: 2 x M20 at top: 2 x M20 lateral: 2 x M20/M25 (1 x each side) |
| Degree of Protection | | IP66, IP67, IP69 |
| Colour | | |
| | | |
| RAL Value | | RAL 7035 |
| Colour | | Enclosure base anthracite |
| Connection to SmartWire-DT | | no |
| For use with | | 3 x Ø 22.5 |
| For use with | | (Illuminated) pushbuttons (Illuminated) selector switches Key-operated pushbuttons Indicator light controlled stop/emergency-stop buttons with yellow label |

Technical data General

| Degree of Protection | | IP66, IP67, IP69 |
|----------------------|----|------------------|
| Ambient temperature | | |
| Open | °C | -25 - +70 |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Heat dissipation per pole, current-dependent | P_{vid} | W | 0.11 |
| Heat dissipation capacity | P _{diss} | W | 1.95 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 70 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Please enquire |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | | |

| 10.2.7 Inscriptions | Meets the product standard's requirements. |
|--|--|
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Enclosure for control circuit devices (EC000200)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Housing for command and alarm devices (ecl@ss10.0.1-27-37-12-05 [AKF023014])

| Construction type housing Material housing Housing material quality Diameter openings Colour housing cover Degree of protection (NEMA) Surface mounting housing Plastic Other Other Grey Grey 13 | (ecl@ss10.0.1-27-37-12-05 [AKF023014]) | | |
|--|--|-----------------------|-----|
| Material housing Housing material quality Diameter openings Colour housing cover Degree of protection (NEMA) Plastic Other Other 22.5 Grey Hogylee of protection (NEMA) 13 | Number of command positions | 3 | |
| Housing material quality Diameter openings Colour housing cover Degree of protection (NEMA) Other Other Other Other Other Other Other Protection (NEMA) Image: 22.5 Grey IP67/IP69K 13 | Construction type housing | Surface mounting hous | ing |
| Diameter openings mm 22.5 Colour housing cover Grey Degree of protection (NEMA) 1967/IP69K 1967/IP69K | Material housing | Plastic | |
| Colour housing cover Grey Degree of protection (NEMA) Grey 13 | Housing material quality | Other | |
| Degree of protection (IP) IP67/IP69K Degree of protection (NEMA) 13 | Diameter openings | mm 22.5 | |
| Degree of protection (NEMA) 13 | Colour housing cover | Grey | |
| | Degree of protection (IP) | IP67/IP69K | |
| NAC-141. | Degree of protection (NEMA) | 13 | |
| width 153 | Width | mm 153 | |
| Height mm 56 | Height | mm 56 | |
| Depth mm 80 | Depth | mm 80 | |

Approvals

| Product Standards | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
|-----------------------------|--|
| UL File No. | E29184 |
| UL Category Control No. | NKCR |
| CSA File No. | 012528 |
| CSA Class No. | 3211-03 |
| North America Certification | UL listed, CSA certified |
| Degree of Protection | UL/CSA Type 3R, 4X, 12, 13 |

Dimensions



Additional product information (links)

| IL04716003Z | AWA1160-1746 | RMQ-Titan System |
|-------------|--------------|------------------|
|-------------|--------------|------------------|

IL04716003Z (AWA1160-1746) RMQ-Titan System $https://es-assets.eaton.com/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716003Z2021_08.pdf$